

Test Report No. [2/01085/21]

Customer Information		Project Information	
Customer	TetraTech International Development	Analysis Order No.	221091401085
		Sampled On	14/09/2021 10:30:00
Samples Count	6	Sample ID(s)	2-2103600 :: 2-2103605
Samples Received on	14/09/2021	Date of Test	14/09/2021
Condition of received sample(s)	Accepted	Sampling	* EL-WQ-SOP-01, EL-WQ-SOP-02
Report Issuance Date	20/09/2021	Tests Fees	Against Contract

Eng. Mwaffaq Al-Khushman

Laboratories Director

20.9.2021

المهندس موفق الخشمان
مدير مديرية مختبرات العقبة الدولية
بن حيان



Test results represent the sample that is sent to BEN HAYYAN - Aqaba International Laboratories by the customer. It may not represent the whole product. This report shall only be reproduced in full with the permission of BEN HAYYAN - Aqaba International Laboratories Management.

Customer: TetraTech International Devel

Test Report No. [2/01085/21]

Samples Received on: 14/09/2021

Test Results:

	Total THMs* Method: (EL-OL-SOP-001) Unit: ug/L	Free Cl2* Method: (EL-WL-SOP-007) Unit: mg/L
(2-2103600) Tala Bay -Marina Inside Central Surface	<16.0	<0.10
(2-2103601) Tala Bay -Marina Inside Central Surface 2	<16.0	<0.10
(2-2103602) Tala Bay -Marina Open Sea Interface Surface	<16.0	<0.10
(2-2103603) Tala Bay -Marina Open Sea Interface Surface 2	<16.0	<0.10
(2-2103604) Tala Bay -Marina Open Sea Interface Bottom 20M Depth	<16.0	<0.10
(2-2103605) Tala Bay -Marina Open Sea Interface Bottom 20M Depth 2	<16.0	<0.10

Approval of Test Results:

(*) Within the accreditation scope
(N.D) Not Detected

Note:

- This test report consists of (3) pages including the cover page. It shall only be reproduced in full. The results are only related to the sample(s) / location(s) mentioned in this report.

- Expanded uncertainty for each reported value (K=2, of 95% probability) is separately provided.



Dr. Abdalmajeed Al-Ajlouni

Water Quality Measurements
Division Head